NOTICE OF SPECIFIED PENALTY				
Date of Issue: October 31, 2022		Payment Due Date: November 30, 2022		
MSA File Number	2022-233	Specified Penalty Amount	\$250	
Market Participant Name	Enfinite Corporation			
Asset ID (if applicable)	ERV2	Self-Report	⊠ YES □ NO	
ISO Rule Section	205.5	Date of Contravention	July 16, 2022	
Date of Referral/Self Report	August 8, 2022	This is the first contravention by this asset for this section of the ISO rules within a rolling 12-month period.		

## **EVENT DETAILS**

On July 16, 2022, at approximately 15:05:42, the ERV2 asset received a directive to provide 20 MW of spinning reserve. Ten minutes following the directive, the quantity of real power provided by ERV2 was less than the directed amount. Section 205.5 of the ISO rules states in part:

10(1) A pool participant must, within ten (10) minutes following receipt of a directive to provide spinning reserve, ensure that its pool asset is providing a quantity of real power equal to the instantaneous amount of real power of the pool asset at the time of the directive and the amount of real power set out in the directive.

#### **FINDINGS**

Based upon the information obtained by the MSA, the MSA is satisfied that the event was a contravention of section 205.5 of the ISO rules.

## **MATERIAL FACTS**

The material facts relied upon by the MSA include the following:

- 1. AESO dispatch, directive, generation, and offer data for ERV2 for July 16, 2022.
- 2. Self-report submitted by Enfinite Corporation to the MSA dated August 8, 2022.

# **DELIVERY OF PAYMENT**

Payment by cheque or certified funds is to be made payable to the "General Revenue Fund c/o Minister of Finance", and delivered to Alberta Energy at: 9945 – 108 Street NW, Edmonton, Alberta, T5K 2G6. The payment should reference this Notice of Specified Penalty and related MSA File #. Electronic copies of the payment and confirmation of delivery should be sent by email to <a href="mailto:compliance@albertamsa.ca">compliance@albertamsa.ca</a> and <a href="mailto:enforcement@auc.ab.ca">enforcement@auc.ab.ca</a>. Questions can be directed to <a href="mailto:compliance@albertamsa.ca">compliance@albertamsa.ca</a>

### NOTICE

The Market Surveillance Administrator (MSA) is granted the power and authority under s. 52 of the *Alberta Utilities Commission Act* to issue a Notice of Specified Penalty where the MSA is satisfied that a person has contravened an ISO rule. Specified penalties are set out in AUC Rule 019.

In accordance with the relevant enactments and rules, a dispute regarding the issuance of a Notice of Specified Penalty or failure to pay the specified penalty in accordance with this notice will result in a hearing or other proceeding before the AUC.

In accordance with s. 5(1) of AUC Rule 019 this Notice of Specified Penalty will be made public no earlier than receipt of confirmation of payment from the Commission and no later than 45 days after issuance. The MSA will, if applicable, also post on its website the link to any decision of the AUC respecting the specified penalty.

If your organization disputes the issuance of this Notice of Specified Penalty, or if you have any other questions or comments regarding this matter, please contact the MSA compliance team at <a href="mailto:compliance@albertamsa.ca">compliance@albertamsa.ca</a>.

SIGNATURE				
Signature	"Original Signed"	Signature Date	October 31, 2022	
Name	Andrew Wilkins	Title	Director, Compliance	